



Owner and Operational Manual



Model: _____

Serial Number: _____

Install Date: _____

Installed By: _____

Service Phone: _____

Sold By: _____

Please read this manual carefully before proceeding with installation. Your failure to follow any of these instructions or operating parameters may lead to personal injury or damage to the equipment and/or personal property. Do not use this Iron Filter system with water that is microbiologically unsafe or of unknown quality, without adequate disinfection before or after the system. This water treatment system contains replaceable treatment components critical for effective performance. It is the user's responsibility to periodically test the product water to verify the system is performing satisfactorily. Failure to properly maintain this water treatment system may cause a health risk.

Save this manual for future reference



Table of Contents

Guardian General Specifications	3
Operating Pressures	3
Operating Temperatures	3
Flow Rate	3
Dimensions	3
Pre-Installation Check List.....	4
Start-Up Instructions	4
Installer Display Settings.....	6
User Display Settings.....	7
Front Cover and Drive Assembly.....	10
Drive Cap Assembly, Downflow Piston, Upflow Piston, Regenerant Piston and Spacer Stack Assembly	11
Injector Cap, Injector Screen, Injector, Plug and O-Ring	12
Refill Control and Check Valve.....	13
Drain Line – 3/4”	14
Water Meter, Meter Plug and Mixing Valve	15
Bypass Valve	16
Service Spanner Wrench.....	17
Troubleshooting.....	19
Ozotech manual.....	20
Water Treatment System Warranty	35

This owner’s manual is designed to assist owners and installers with the operation, maintenance and installation of your new water filter. Detailed instructions on general operating conditions, installation instructions, start-up, and programming are included. A troubleshooting guide, service instructions and parts diagrams are also included to assist with future needs.

Please contact the dealer who installed the system if you need professional assistance in service of your water filter.

Guardian General Specifications

Inlet/Outlet.....1"
Cycles.....3
Valve MaterialNoryl©

Operating Pressures

Minimum/Maximum40 - 80psi
Optimal Range.....40 - 60psi

***Pump output must meet or exceed backwash rate.**

Operating Temperatures

Minimum/Maximum40° - 110°F

Flow Rate

Guardian 150 Series5 - 9 gpm
Guardian 250 Series9 - 14 gpm

Dimensions

Drain Line $\frac{3}{4}$ " or 1" NPT
Electrical Current Draw and Voltage120V/15VDC

* Operating outside of the optimum pressure range may affect system functionality. Contact your dealer for more information.

** Guardian Series not to be used with micro-biologically unsafe water sources

Pre-Installation Check List

(All electrical and plumbing should be done in accordance to all local codes)

Guardian Series is acceptable for indoor use only

Water Quality: Sand and sediment are often problems in rural water supplies. They may plug the filter and restrict water flow through the media bed. Well and/or pump problems affecting the operation of the filter and repairs are not covered under warranty.

Water Pressure: A minimum of 40 pounds of water pressure (psi) is required for operation. Maximum pressure is 80 psi.

Water Temperature: Filter water temperature must not exceed 110°F or be subject to freezing.

Existing Plumbing: Must be free from build-up. If plumbing is blocked, it must be replaced or additional equipment may be needed ahead of filter.

Electrical: All electrical connections must be connected per local codes. A continuous 110 volt supply is required.

Drain Line: Filter should be located near drain. Do not use overhead drain lines as possible back pressure may occur. Pipe size should be a minimum of ¾" for the drain.

Bypass Valves: Always allow for installation of a bypass valve.


Start-Up Instructions

***For optimal results, the filter media should be soaked for 12 hours prior to installation.**


1. Complete all plumbing connections; inlet, outlet, and drain line.
2. Place bypass in bypass position. Turn on main water supply and open a cold filtered faucet to clear lines of air or obstructions.
3. Plug unit into a 120-volt outlet. Valve will move to service position once connection is made.
4. Start a backwash cycle by holding the "REGEN" button down until valve movement is heard.
5. Slowly open inlet valve on bypass until it is fully in open position. Allow water to run to the drain until clear.
6. Allow system to continue going through all the cycles.
7. Filter is ready for use after first regeneration cycle is complete.

BYPASS VALVE OPERATION


NORMAL OPERATION




BYPASS OPERATION



DIAGNOSTIC MODE




SHUT OFF MODE




Installer Display Settings

STEP 1I



STEP 1I - Press NEXT and ▲ simultaneously for 3 seconds.

STEP 3I




STEP 3I – Day Override: When volume capacity is set to “OFF”, sets the number of days between regenerations. When volume capacity is set to AUTO or to a number, sets the maximum number of days between regenerations. If value set to “OFF”, regeneration initiation is based solely on volume used. If value is set as a number (allowable range from 1 to 28) a regeneration initiation will be called for on that day even if sufficient volume of water were not used to call for a regeneration. Set Day Override using ▼ or ▲:

- number of days between regeneration (1 to 28); or
- “OFF”.


See Setting Options Table for more detail on setup. Press NEXT to go to step 4I. Press REGEN to return to previous step.

STEP 4I




STEP 4I – Next Regeneration Time (hour): Set the hour of day for regeneration using ▼ or ▲. AM/PM toggles after 12. The default time is 2:00 AM. This display will not appear if IMMEDIATE is selected in Set Regeneration Time Option in OEM Softener System Setup Step 10S. Press NEXT to go to step 5I. Press REGEN to return to previous step.

STEP 5I



STEP 5I – Next Regeneration Time (minutes): Set the minutes of day for regeneration using ▼ or ▲. This display will not be shown if IMMEDIATE is selected in Set Regeneration Time Option in OEM Softener System Setup Step 10S. Press NEXT to go to Step 6I. Press REGEN to return to previous step.

STEP 6I



STEP 6I – As an energy-saving feature, the control will automatically turn off the display illumination after 5 minutes of keypad inactivity. Any further keypad activity or water use will re-illuminate the display for 5 minutes. The Energy Saver feature default is ON. Press NEXT to exit Installer Display Settings. Press REGEN to return to previous step.

RETURN TO NORMAL MODE

User Display Settings

General Operation


When the system is operating, one of several displays may be shown. The displays normally rotate, however pressing NEXT will pause on the selected display for 5 minutes. Pressing NEXT will alternate between the displays. One of the displays is always the current time of day. Days Remaining is the number of days left before the system goes through a regeneration cycle. Gallons Remaining is the gallons that will be treated before the system goes through a regeneration cycle.

Pressing ▼ while in the Gallons Remaining display will decrease the capacity remaining in 10 gallon increments and will also increase the volume used impacting the recorded values in Diagnostics Steps 3D, 4D and 5D and Valve History, Step 4VH.

Another display shows the current treated water flow rate through the system. Either REGENERATION DP or REGENERATION HOLD will be displayed if the dP switch is closed. To clear the Service Call reminder, press ▲ and ▼ simultaneously while the number and banner text screen is displayed.

If the system has called for a regeneration that will occur at the preset time of regeneration, the words REGEN TODAY will alternate with the header on the display.

If a water meter is installed, the flow indicator flashes on the display when water is being treated (i.e. water is flowing through the system).



Regeneration Mode


Typically a system is set to regenerate at a time of low water usage. An example of a time with low water usage is when a household is asleep. If there is a demand for water when the system is regenerating, untreated water will be used.



When the system begins to regenerate, the display will change to include information about the step of the regeneration process and the time remaining for that step to be completed. The system runs through the steps automatically and will reset itself to provide treated water when the regeneration has been completed.

Manual Regeneration

Sometimes there is a need to regenerate the system sooner than when the system calls for it, usually referred to as manual regeneration. There may be a period of heavy water usage because of guests or a heavy laundry day.




To initiate a manual regeneration at the preset delayed regeneration time, when the regeneration time option is set to DELAYED REGENERATION or DELAY + IMMEDIATE REGENERATION, press and release REGEN. The words REGEN TODAY will periodically be shown on the display to indicate that the system will regenerate at the preset delayed regeneration time. If you pressed the REGEN button in error, pressing the button again will cancel the request. Note: If the regeneration time option is set to IMMEDIATE REGENERATION there is no set delayed regeneration time so REGEN TODAY will not activate if REGEN is pressed.

To initiate a manual regeneration immediately, press and hold the REGEN button for three seconds. The system will begin to regenerate immediately. The request cannot be cancelled.

Note: For softeners, if brine tank does not contain salt, fill with salt and wait at least two hours before regenerating.

Set Time of Day

The user can also set the time of day. Time of day should only need to be set if the battery has been depleted because of extended power outages or when daylight saving time begins or ends. If an extended power outage occurs, the time of day will flash on and off which indicates the time of day should be reset. The non rechargeable battery should also be replaced.




Power Loss

If the power goes out the system will keep time until the battery is depleted. If an extended power outage occurs, the time of day will flash on and off which indicates the time of day should be reset and the non rechargeable battery replaced. The system will remember the rest.

Error Message

If the word “ERROR” and a number are displayed contact the OEM for help. This indicates that the valve was not able to function properly. If the number and banner text in the Contact Screens has been edited, the two displays below will alternate.



Front Cover and Drive Assembly

Drawing No.	Order No.	Description	Quantity
1	V4441-01	COVER ASY	1
2	V3107-01	MOTOR ASY	1
3	V3002-A	DRIVE BRACKET ASY	1
4	V4461FB-BOARD	THRU2 FB PCB REPLACE	1
5	V3110	DRIVE REDUCING GEAR 12X36	3
6	V3109	DRIVE GEAR COVER	1
Not Shown	V3186-06	POWER SUPPLY US 15VDC HOCP	1
	V3186AUS-05OD	POWER SUPPLY AUS 15VDC VI OUTDOOR	
	V3186EU-06	POWER SUPPLY EU 15VDC HOCP	
	V3186UK-06	POWER SUPPLY UK 15VDC HOCP	
	V3186-01	POWER CORD ONLY	
Not Shown	V3946	WIDE DRIVE BACK PLATE	1


Refer to Control Valve Service Manual for other drawings and part numbers.

Relay Specifications: 12V DC Relay with a coil resistance not less than 80 ohms. If mounting relay under the cover check for proper mounting dimensions on the backplate.

Power Supply	U.S.	International
Supply Voltage	100-120 VAC	100-240 VAC
Supply Frequency	50/60 Hz	50/60 Hz
Output Voltage	15 VDC	15 VDC
Output Current	500 mA	500 mA

Wiring for Correct On/Off Operation	
PC Board Relay Terminal Block	Relay
RLY 1	Coil -
V +	Coil +
RLY 2	Coil -

When replacing the battery, align positives and push down to fully seat.




Drive Cap Assembly, Downflow Piston, Upflow Piston, Regenerant Piston and Spacer Stack Assembly

Drawing No.	Order No.	Description	Quantity
1	V3005-02	Spacer Stack Assembly	1
2	V3004	Drive Cap ASY	1
3	V3946	Refer to Programming and Cover Drawing Manual	1
4a	V3011*	Piston DownflowASY	1
5	V3174	Regenerant Piston	1
6	V3135	O-ring 228	1
7	V3180	O-ring 337	1
8	V3105	O-ring 215 (Distributor Tube)	1
Not Shown	V3001	Body ASY Downflow	1


*V3011 is labeled with DN and V3011-01 is labeled with UP. Upflow option is not applicable to TC control valves.

Note: The regenerant piston is not used in backwash only applications.




Injector Cap, Injector Screen, Injector, Plug and O-Ring

Drawing No.	Order No.	Description	Quantity
1	V3176	Injector Cap	1
2	V3152	O-Ring 135	1
3	V3177-01	Injector Screen Cage	1
4	V3010-1X	Injector Asy (Specify Tank Size)	1




Refill Control and Check Valve

Drawing No.	Order No.	Description	Quantity
1	H4615	Elbow Locking Clip	1
2	V4144	Elbow 3/8" Liquifit	1
3	V3163	O-ring 019	1
4	NeoOV15	15 MM Check Valve	1
5	V4144-01CV	Elbow 3/8 Liquifit Asy w/RFC	1
6	ABPUS1	Brine Screen with Tube	1



Drain Line – 3/4"

Drawing No.	Order No.	Description	Quantity
1	H4615	Elbow Locking Clip	1
2	V3962	Drain Elbow ¾ Male	1
3	V3163	O-ring 019	1
4	V3159-01	DLFC Retainer ASY	1
5	V3162-xxx	DLFC Based Upon tank and media used	One DLFC must be used if ¾ fitting is used




Water Meter, Meter Plug and Mixing Valve

Drawing No.	Order No.	Description	Quantity
1	V3151	Nut 1" QC	1
2	V3003-05*	Meter ASY	1
3	V3118-01	Turbine ASY	1
4	V3105	O-ring 215	1
5	V3003-01	Meter Plug ASY	1

*Order number V3003 includes V3118-01 AM1 Turbine ASY and V3105 O-ring 215.

THIS WATER METER SHOULD NOT BE USED AS THE PRIMARY MONITORING DEVICE FOR CRITICAL OR HEALTH EFFECT APPLICATIONS.




Bypass Valve

Drawing No.	Order No.	Description	Quantity
1	V3151	Nut 1" Quick Connect	2
2	V3150	Split Ring	2
3	V3105	O-Ring 215	2
4	V3145	Bypass 1" Rotor	2
5	V3146	Bypass Cap	2
6	V3147	Bypass Handle	2
7	V3148	Bypass Rotor Seal Retainer	2
8	V3152	O-ring 135	2
9	V3155	O-ring 112	2
10	V3156	O-ring 214	2

(Not Shown) Order No. V3191-01, Description: AM1 Bypass Vertical Adapter Assembly


Order No.	Description	Quantity
V3151	Nut 1" Quick Connect	2
V3150	Split Ring	2
V3105	O-Ring 215	2
V3191	Bypass Vertical Adapter	2




Service Spanner Wrench

(Order No. V3193-02)

Although no tools are necessary to assemble or disassemble the valve, the WS1 wrench (shown in various positions on the valve) may be purchased to aid in assembly or disassembly.



<u>Item</u>	<u>Quantity</u>	<u>Part Number</u>	<u>Description</u>
1	1	CIOX-V1FBDTF	CIOX Valve
2	1	ENDT	Distributor Tube
3	1	EN104 * VT	Vortech Mineral Tank
		EN1354 * VT	Vortech Mineral Tank
4-5	1.5/2.5	***	Filter Media
6	1	D1047	Air Blocker
7	1	V3006	Bypass Assembly
8	1	V3191-01CV	Elbow Assembly with CV**
9	1	V4144-01CV	Brine Elbow with CV
10	1	V3962	Drain Assembly




***Black or natural color**

****Must be installed in downward position**

*****Consult dealer for correct media replacement**

Troubleshooting

Problem	Cause	Solution
1. Blank or unreadable LCD display	A. Transformer unplugged B. Defective transformer C. No electric power at outlet D. Check battery in valve E. PC board is defective	A. Connect to Power B. Check to ensure 12 volt motor, replace transformer C. Repair outlet or switch to working outlet D. Replace battery if less than 3 volts E. Replace PC Board
2. Control valve stalled in regeneration	A. Broken drive gear or drive cap assembly B. Broken regenerant piston C. Broken main piston D. Motor not operating correctly E. Defective transformer F. No power to unit	A. Replace drive gear or drive cap assembly B. Replace regenerant piston C. Replace main piston D. Replace motor E. Check to ensure 12 volt motor, replace transformer F. Ensure working outlet
3. Control valve regenerates at wrong time of day	A. Power outages B. Time of day not set correctly C. Control valve is programmed incorrectly	A. Reset time of day, replace lithium coin type battery on circuit board B. Reset time of day C. Check control valve programming procedure
4. Odor/Color noticed on outlet of filter	A. Perform water analysis B. Determine if filter media needs replacing	A. Increase regeneration time. a. Exceeding flow rate specification B. Replace filter media
5. Reduction of water pressure	A. Determine if filter media needs replacing	A. Replace filter media



OzotechEOG

Enhanced Oxidation Generator



Installation and Service Manual

Table of Contents

1.0	Limited Warranty	4
2.0	Service Returns	5
3.0	Caution	6
4.0	Installation and Operation	7
	4.1 Operating Environment	7
	4.2 Installation	8-9
	4.3 Operation	10
5.0	Maintenance	11
	5.1 Ozone Generator Maintenance	12-13
6.0	Spare/Replacement Parts	14
7.0	Specifications	14
8.0	Component Replacement	15
9.0	Troubleshooting Guide	15
10.0	Illustrations	16
	Figure 1. OzotechEOG internal layout	16

1.0 Limited Warranty

Ozotech, Inc., warrants the OzotechEOG series ozone generators to be free from defects in parts and workmanship for (12) months from date of invoice, under conditions of normal use. The corona discharge (CD) cell is warranted against catastrophic electrical failure for 3 years from date of invoice. All other parts, repaired or replaced, will be warranted only for the remainder of the original warranty period.

Ozotech, Incorporated will refund the purchase price, perform repairs or replace equipment, at the option of Ozotech, Incorporated.

The warranty shall be null, void, and non-binding upon Ozotech, Incorporated if Ozotech, Incorporated (or authorized service center) determines the cause of malfunction or defect to be a result of:

- 1)** Failure to perform proper maintenance as defined and recommended in this manual.
- 2)** Failure to adhere to and provide proper operating conditions, as defined in this manual, including operation outside of temperature range, operating in wet or dirty environment, operation outside of manufacturer's specifications.
- 3)** Adjustments made by user other than product output flow rate within ranges specified by manufacturer.

Ozotech, Incorporated assumes no liability for damages incurred by deliberate or incidental misuse of this product, or damages incurred in transit.

2.0 Service Returns

If the need arises to return your equipment for service, the following procedure must be followed to ensure accurate and timely processing of repairs.

- ✓ Obtain model number/name of unit to be returned.
- ✓ Contact Ozotech, Inc and request a Return Material Authorization (RMA) form. Make sure to give the factory representative an accurate and current shipping address.
- ✓ Provide a description detailing the problem with the unit. Be as specific as possible.
- ✓ After receipt of RMA form, package unit for shipment. Enclose the RMA form with the unit. Use the original packaging materials if possible. If not, please package the product to ensure against shipping damage.
- ✓ Clearly write the RMA number on the outside of the shipping package.
- ✓ Verify that the address is correct and current.
- ✓ Shipments that are not factory authorized will be refused.

It is recommended that you ship with a reputable and reliable shipping company, and that the contents of the package are insured. Ozotech, Inc. accepts no responsibility for damage or loss of equipment in transit.

ALL FREIGHT CHARGES INTO THE FACTORY MUST BE PREPAID. If the repair is covered under warranty, the factory will pay return shipping charges (surface rates only) to the address listed on the RMA, within the Continental United States.

If the repair is not covered under warranty, the returning party is responsible for payment of return shipping and handling charges, as well as labor and equipment costs associated with the repair.

3.0 Caution



Read the following safety guidelines thoroughly before attempting to operate or install your equipment.



As with all electrical devices, this equipment should never be allowed to come in contact with water.



Only qualified personnel should be allowed to set up, maintain and operate this equipment.



The equipment must be operated using a properly grounded electrical circuit that is protected by either a fuse or circuit breaker.



Do not use an extension cord to supply power to this equipment.

* Ozotech, Inc., assumes no liability for damages or injuries incurred by misuse of this product.

4.0 Installation and Operation

Your generator requires special operating conditions in order to maintain performance and reliability. Your ozone generator is designed to be operated under a negative pressure situation.

Warranty coverage of your equipment is contingent upon strict compliance with the operating conditions specified in this manual.

4.1 Operating Environment

External

It is most important to choose a cool, clean external operating environment. Consideration of these factors should be a priority. Mount your ozone generator in the best possible operating environment that is available at the chosen site. If possible, mount in an area that is free of airborne moisture particles.

Internal

Keep the inside of the generator chassis clean and dry. Dust particles and condensation pose a challenge to the consistent operation of all ozone generators. Make a note to inspect the internal cleanliness of the equipment when scheduled maintenance is performed. For further information, refer to section 5.0.

4.2 Installation

1. Mount the OzotechEOG to the Clack® control valve. A #2 Philips screwdriver will be required.
 - a. Install clamp ring into OzotechEOG backplate receiver.
 - b. Install port clip into OzotechEOG backplate receiver.
 - c. Loosen clamp screw, slide clamp over valve injector cap. Rotate OzotechEOG counterclockwise to secure port clip. Tighten clamp screw.



2. Disconnect power to the control valve. Remove the front cover from valve backplate. Release the control board bracket from backplate.



3. Route the grey control wire from the OzotechEOG into Clack® valve housing through the hole in the backplate, and through the strain relief channel above to keep wiring in place.
 - a. Leave enough wire length to connect to the signal relay terminal block of the control circuit board. Make sure the wire is flush in the channel for proper bracket installation.
 - b. Replace the control board bracket into backplate until it "snaps" into place.

4.2 Installation Continued

4. Secure red wire into RLY 1 terminal, and black wire into +COM terminal on Clack® control board.
5. Replace control valve front cover.
6. Plug the supplied wall transformer into a wall outlet. Plug the male DC plug into the female DC jack located at the back of the OzotechEOG. Press alarm reset button on OzotechEOG PCB to reset 365 day maintenance timer.
7. Program ozone start and end schedule using control valve PCB.
 - a. Enter cycle programming mode
 - b. Set backwash to 14 minutes
 - c. Set draw time to 40 minutes
 - d. Turn off fill
 - e. Turn off rinse
 - f. Set relay to "on"
 - g. Set the relay on time to 15 minutes (one minute longer than backwash)
 - h. Set the relay duration for 38 minutes (2 minutes less than draw time)
 - i. Return to service
 - j. Press regeneration button to lock in timing

4.3 Operation

The OzotechEOG will automatically turn on and off by the Clack® control PCB defined timing schedule. The OzotechEOG control board utilizes an onboard diagnostic LED light to convey real-time performance status of the unit. The control board within the OzotechEOG has several inputs and outputs. The following will address functions of the diagnostic LED, control input, and auxiliary outputs.

LED Diagnostic Functions:

Green Light Blinking Slowly: Standby mode; unit is powered, pilot input is OFF.

Green Light Blinking Quickly: High voltage startup (up to 3 seconds).

Green Light Solid: High voltage is ON & stable; CD cell producing ozone.

Red Light Solid: Unstable operation; CD cell may need cleaning.

Green/Red Light Alternating Twice/Second: HV is ON, but operating current is low. If persistent, CD cell may need cleaning.

Red Light Flashing: NO or NC contacts are shorted. Remove short condition.

Orange Light: 1-year timer has expired; clean CD cell, then reset timer by pressing red "alarm reset" button on PCB once.

4.3 Operation Continued

Control Input:

The OzotechEOG PCB is activated to produce ozone when a pilot input signal is applied across "+" & "pilot" terminals.

Auxiliary Output Functions:

The NO/NC auxiliary outputs have a 3 second off-delay, after the pilot signal is shut off. These outputs are capable of outputting a maximum of 60mA @ 70°F and are intended to be used as a control circuit only. Attach positive wire to NO or NC output terminal, and negative wire to GND terminal to complete the desired circuit. See figure 1, on page 14 for auxiliary output locations.

Fusing:

The control PCB is equipped with automatically resetting on-board fuses. If these fuses trip, due to a short of the HV transformer, or excessive load on the auxiliary output(s), remove excessive load/cause of short, and cycle main power on/off to reset. If the HV transformer is shorted, the LED indicator will stay solid red until condition is remedied. If either NO or NC output is active and experiences excessive load, the LED indicator will quickly flash red until condition is removed.

5.0 Maintenance

The OzotechEOG ozone generator is delivered factory tested, calibrated, and adjusted for maximum efficiency and long life. Simple maintenance and appropriate operating conditions are the only requirements to keep the unit functioning within manufacturer's specifications.

Performing any other modifications or adjustments to internal components will cause the unit to function outside of manufacturer's specifications and will cause damage to the unit not covered under warranty terms.

5.1 Ozone Generator Maintenance

Frequency of Maintenance: **Every 12 months, more frequently in high humidity areas.**

Perform the following CD cell cleaning procedure:

Note: A CD cell cleaning kit may be purchased from Ozotech, Inc. Reference section 6.0 for more information.

***CAUTION:** UNPLUG POWER SUPPLY TO OzotechEOG BEFORE PERFORMING SERVICE*

1. With the front cover removed, remove the CD cell from the ozone generator:
 - a. Disconnect the red spade terminal connector from the CD cell connection terminal.
 - b. Cut the CD cell retaining strap holding the cell into the cell clips, and discard.
 - c. Disconnect the air inlet and ozone outlet hoses from the CD cell barb fittings.
 - d. Pull the CD cell straight up from the retaining clips.
2. Flush the CD cell with warm water until the water comes out entirely clean:
 - a. Connect a 3/16" I.D. piece of tubing to either of the CD cell barb fittings.
 - b. Using a syringe or rubber bulb pump to work the warm water through the CD cell, flushing until all nitric acid or obstructions are removed, and the water runs clean.
(NOTE: Hot water can be used if nitric acid buildup is severe)
3. Ensure that the CD cell is completely dry, inside and out, before re-installation:
 - a. Use dry, compressed air to blow through either CD cell barbed fitting until no moisture is ejected from the opposite barbed fitting.

5.1 Ozone Generator Maintenance Cont.

4. Reinstall clean, dry CD cell into OzotechEOG in reverse order, making sure all air and electrical connections are secure.

Frequency of Maintenance: Every 12 months

Perform the following general maintenance and CD cell cleaning procedure:

1. Disconnect OzotechEOG from power source.
2. Remove cover.
3. Inspect the inside of the generator for dust and moisture.
4. Thoroughly clean and dry the inside of the generator.
5. Replace top cover.
6. Replace any inline and brine elbow check valves.

Maintenance timer service reset instructions:

Normally the EOG II controller board will signal cell maintenance is due by changing the LED indicator light to an orange color, once service has been performed then the timer will be reset simply by pressing the "Alarm Reset" button.

However, if a technician services or replaces the cell prior to the 1-year service signal is displayed, a "forced reset" on the timer should be performed.

Follow these instructions to do the reset...

1. Power off device by removing DC plug from back of EOG.
2. Remove front cover to access circuit board.
3. Find and press "Alarm Reset" button. Continuing to hold reset button, return power to device by plugging power plug back in. Hold button for 3 seconds, no indicator lights should be on.
4. After 3 seconds, release button. LED indicator light should pulse slowly in an orange-red color. This indicates maintenance timer reset function has been triggered.

Note: If a technician wants to abort the reset, power cycle device again without pressing any buttons now and original condition will be restored.

5. Press alarm reset button again to reset maintenance timer. LED should turn green.
6. EOG is now ready to operate as normal.

Notes: This feature only applies to EOGs made after May 2020

(See program rev code on side of transformer and or date code in serial number).

6.0 Spare/Replacement Parts

Part #	Description
33218	Replacement CD cell, w/tubing
47035	Ozone resistant inline check valve* (1)
40080-03	Wall transformer, 120/240VAC to 12VDC, regulated (domestic customers only)
47044-1	Kit, CD cell maintenance

* Denotes recommended spare maintenance parts with initial purchase. Followed by additional quantity recommended for one year's scheduled maintenance.

7.0 Specifications

Input Power Requirements:

Operating Voltage: 12VDC via 120/240VAC 50/60Hz switching power supply

Power Consumption: 600mA @ 12VDC (7.2 watts) nominal

Size (L x W x H): 6.8" x 4.4" 5.4"

Shipping Weight: 2 lbs.

Ozone Output: 220 mg/hr.

Enclosure: ABS

8.0 Component Replacement

CD Cell Replacement

CAUTION: UNPLUG POWER SUPPLY TO OzotechEOG BEFORE PERFORMING SERVICE


1. With the front cover removed, remove the CD cell from the ozone generator:
 - a. Disconnect the red spadeterminal connector from the CD cell connection terminal.
 - b. Cut the CD cell retaining strap holding the cell into the cell clips, and discard.
 - c. Disconnect the air inlet and ozone outlet hoses from the CD cell barb fittings.
 - d. Pull the CD cell straight up from the retaining clips.
2. Replace with new CD cell in reverse order, making sure all air and electrical connections are secure.

9.0 Troubleshooting Guide

System	Possible Cause	Solution
Unit doesn't turn on	Unit is not connected to power source, or is connected to improper power source	Refer to input power requirements on pg. 12, and Figure 1 on pg. 14 for proper electrical connections.
	Electrical short circuit	Visually inspect unit and check for loose connections. Inspect printed circuit board (PCB) for burn marks. Inspect HV wire from PCB to CD cell for disconnection or burn marks. Repair any and all problems prior to placing unit back into service, or contact factory for service.
	Unit is connected to improper power source	Refer to pg. 12 to ensure that unit is plugged into proper voltage outlet.
Unit turns on, but no ozone output	Frequency driver is defective	Replace PCB board.
	Frequency driver high voltage lead not connected to ozone cell	Connect red flag terminal to CD cell spade connection.
	Water has been allowed to back up into the CD cell and has caused a direct short	Dry CD cell using drying procedure on pg. 10. Replace CD cell.
	Cell is plugged with build-up of nitrous byproducts and particulate matter. Usually caused by the lack of proper air preparation	Refer to section 5.1 on pg. 10 to clean CD cell. Replace CD cell.

10.0 Illustrations

Figure 1: OzotechEOG internal layout



Water Treatment System Warranty

This quality FRAKCO Iron Filter is designed and built to provide many years of satisfactory performance under normal use. FRAKCO, INC. pledges to the original owner that for sixty months, all non-wearable items of the above-described water treatment system proven to be defective due to workmanship and/or materials will be replaced or repaired. FRAKCO also pledges that the fiberglass media tank is covered under this warranty for ten years if owned by the original purchaser. Our pledge does not apply if the damage is caused by defective installation; water pressure in excess of eighty pounds per square inch; water temperature in excess of 110° F.; misuse; unauthorized alterations; freezing; accident; fire; neglect; or damage caused by shipping.

To obtain service under this warranty, notify FRAKCO, INC. in writing of any defects in workmanship within thirty days of the appearance of such defects. Such written notice must include the date of purchase, the part number, and a description of the defect. Upon receiving such notice and determining that the defect is covered by this warranty, FRAKCO, INC. will replace or repair the defective item.

Replacement of a defective item will be at FRAKCO'S factory in Luverne, MN, and the purchaser must ship the defective item at its own expense to FRAKCO'S factory. Replacement items will be shipped by FRAKCO F.O.B. Luverne, Minnesota, with a shipping carton furnished. In the event certain models or colors of the replacement item are out of stock, FRAKCO, INC. may, after notifying the purchaser, furnish another model or color of the replacement item. The factory will not pay for service charges and will not perform any repair or service functions other than at its home office.

Please follow the enclosed instructions and local codes in installing your water treatment system. Failure to do so will void this warranty. Nothing in the warranty may be construed as involving the factory in the relationship between Dealer and Owner.

This warranty gives the purchaser specific legal rights. The purchase may also have implied warranty rights. In the event of a problem with warranty service or performance, the purchaser may be able to go to a Small Claims Court, a State Court, or a Federal District Court. This warranty complies with the 1975 Federal Warranty Law.

Model No. _____ Serial No. _____

Date Installed _____ Dealer _____

Address _____

*MANUFACTURED BY: FRAKCO, INC.
500 N BLUE MOUND AVE
LIVERNE, MINNESOTA 56156
WWW.FRAKCO.COM*